

# Certificate of Assessment

HF38-2003-002

No. 450

"Copyright CSIRO 2004 ©"

Copying or alteration of this report  
without written authorisation from CSIRO is forbidden.

This is to certify that the specimen described below was tested by the CSIRO Division of Manufacturing and Infrastructure Technology in accordance with Australian/ New Zealand Standard 3837, Method of test for heat and smoke release rates for materials and products using an oxygen consumption calorimeter, 1998, at 50 kW/m<sup>2</sup>, on behalf of:

Regina Glass Fibre Pty Ltd  
215 Williamsons Road  
Templestowe VIC 3106  
AUSTRALIA

A full description of the test specimen and the complete test results are detailed in the Division's research report numbered CMIT(C)-2004-011.


SAMPLE IDENTIFICATION: P500PVB Regina Glass Fibre.

DESCRIPTION OF SAMPLE: The sponsor described the tested specimen as an insulation facing mat adhered to glass-fibre insulation using National Starch 286-1654 at an application rate of 40 g/m<sup>2</sup>.

Nominal thickness: 0.50 mm  
Nominal mass: 60 - 65 g/m<sup>2</sup>

SAMPLE CLASSIFICATION: Group Number: Group 1  
(In accordance with Specification A2.4 of the Building Code of Australia.)  
Average specific extinction area: 14 m<sup>2</sup>/kg  
(Refer to Specification C1.10a section 3(c) of the Building Code of Australia.)

Testing Officer: Brad Paroz Date of Test: 7 November 2003  
Issued on the 15<sup>th</sup> day of January 2004 without alterations or additions.



Garry E Collins  
Manager, Fire Testing and Assessments



*Improving the Built Environment*

Building, Construction and Engineering

14 Julius Avenue, Riverside Corporate Park, Delhi Road, North Ryde NSW 2113 AUSTRALIA  
Telephone: 61 2 9490 5444 Facsimile: 61 2 9490 5555